FOR MYSORE STATE

(Public Works) **(1955) Department.**

G.O. NO. (Ms.2838) 2838

Dated (25th July 1955) 25-7-'55

✓ [Despatch Abstract.]

Electricity - Restriction and Control - Mangalore Electric Supply Co. Ltd - Supply to Government Ice and Fish Freezing Plant, Mangalore - Permitted.

ELECTRICITY DEPARTMENT.

From
Sri K.M.Kuruwilla,
Chief Electrical Inspector
to Government,
157, Mount Road, Madras-2.

To
The Secretary to Government,
Public Works Department,
Madras.

No. 634 R/55-7 dated 15--6--55.

Sir,



Sub: ELECTRICITY - Restriction and Control - Supply to Government Ice Plant, Mangalore.
Ref: Application No.MAN/1252/67/3 dated 11-6-55 from M/s Mangalore Electric Supply Co., Ltd., Mangalore.

I enclose herewith 3 copies of the above, for permit for supply to a load of 128 H.P. for the Government Ice and Fish Freezing Plant, Mangalore, represented by the Director of Industries and Commerce, Madras, as the same exceeds the powers of sanction of this office, the load being in excess of 50 K.W. Though supply is required for a connected load of 128 H.P. the licensee is not in a position to supply more than 60 K.W. at L.T. voltage. Further, supply is required all the 24 hours. I therefore request that the licensee may be permitted to effect unrestricted supply to the above load subject to the following conditions:-

1. The maximum demand of the consumer should be restricted to 60 K.W. at all times.

2. Supply is liable to be suitably restricted, staggered or cut off altogether as the case may be as and when the power position or any other emergency in the licensee's power house, warrants such a course of action.

Yours faithfully,

Chief Electrical Inspector to Government

Government of Madras.
Public Works Department.

Endorsement No. 51657-P/55-1 dt 21st June 1957.

Forwarded to the Chief Operation Engineer (South) for remarks.

21.6.57

(V.M. VAIDYANATHAN)
Assistant Secretary to Govt.

21.6.55

To
The Chief Operation Engineer (South),
157, Mount Road, Madras-2.

Lr. No. 2311
Encls. in original to be retd. with reply.
(4 sheets)

Ref. No. MAN/1252/67/3 Dated 11-6-1955

The Mangalore Electric Supply Company, Limited.

Application for permit for Electric Supply for prospective consumers whose requirements are 50 K. W. and less

13537

Office of the Chief Electrical Inspector & Chief Electrical Engineer
14 JUN
Section
C. No. 2043

1.	Name of Electric Supply Undertaking.	The Mangalore Electric Supply Co., Ltd.
2.	Registered Address.	No. 14, Old Court House Street, Calcutta.
3.	Name & Reg. Address of Consumer.	Director of Industries & Commerce, Madras, for Government Ice and Fish Freezing Plant in Mangalore.
4.	Premises for which supply is required and its address.	~~Residential~~ / ~~Industrial~~ / Public Building. Govt. Ice and Fish Freezing Plant at Hoige Bazaar.
5.	Present maximum demand (if any).	Nil
6.	Estimated additional maximum demand required by consumer and for which application is now being made.	60•0 K. W.
7.	Is it practicable to arrange the consumer's operation so that the demand in (6) will not occur during the peak load period of the Undertaking.	Yes.
8.	By how much is it estimated that the (undertaking's) maximum demand will increase by the proposed consumer's load.	60.0 K. W.
9.	Connected load to be installed.	Lighting ..... Motors 128 H.P. Others .....
10.	Industry to be served (indicate the product to be manufactured and whether this is expansion of present production or new products).	Government Ice and Fish Freezing Plant.
11.	Is factory to work one, two or three shifts per day.	24 hours.
12.	If consumer's plant is ready to take supply, give date when it was ready for supply, if not, state when it will be ready.	yes.
13.	If products are orders of Department of supply please specify and attach as evidence copy of letter from department concerned.	Copy of letter No.R.C.49/51 dt.17-5-5 from the Fisheries Refrigeration Engineer is enclosed. 6.3.55 *Signature of Consumer.* Fisheries Refrigeration Engineer for Director of Industries & Commerce Madras

Remarks of supply undertaking.

14.	(a) Capacity of existing service connection (if any).	Nil
	(b) Is required service D. C. or A. C. High or low voltage.	A. C. 400 Volts 3 Phase
	(c) Brief list of main materials required for service connection.	Meter Board .. 1 Cutouts 100Amps .. 3 Superite cable 19/.083 S.C. 80 ft. GI Pipe 2" .. 20 " GI Wire No.8 .. 16 lbs. BC Wire 1/0 S.W.G. .. 180 " Pole .. 1 100 Amps. 3 Phase Meter 1

14-6

(d) Approximate cost of giving service.	Rs. 2,47
(e) Are all materials available in the stores of the Undertaking.	Yes.
(f) What prime movers (if any) will be displaced by giving supply of electric power. Give type and condition of any such engines which would be displaced.	None.
(g) Any other remarks by the undertaking on effect of this service on the system.	The Director of Industries & Commerce has decided to take L.T.Supply. As the Company, however, cannot give L.T.Supply to a connected load of 128 H.P., the party has agreed to restrict the M.D. to 60 K.Ws.in which case the Company can arrange to give L.T.Supply. The application may therefore be sanctioned for 24 hours' supply subject to the condition that the maximum demand of the installation ~~should~~ does not exceed 60 K.Ws.
	CHIEF ENGINEER (Elec) Signature of Licensee.
15. Remarks of Chief Electrical Inspector to Government on the essentiality of supply.	
16. Orders of the Chief Electrical Inspector. (in case of Ty. supplies).	*Signature of Chief Electrical Inspector to Government.*
17. Orders of the Provincial Government.	

GOVERNMENT ELECTRICITY DEPARTMENT.

--

From
The Chief Operation Engineer (South),
157, Mount Road, M a d r a s.

56850

To
The Secretary to Government,
Public Works Department, Madras.



No.2311-E/55-F Dated 30-6-55.

Sir,

Sub:- Electricity - Restriction and Control - Supply to Government Ice Plant, Mangalore.

Ref:- Government Endt.No.51657-P/55-1 dated 21-6-55

The Mangalore Electric Supply Company Limited, Mangalor may be permitted to effect the supply subject to the conditions stipulated by the Chief Electrical Inspector to Government in his letter No.634-R/55-7 dated 15-6-55 to Government

2. As the licensee is not taking power from the department, I have no special remarks to offer.

3. The Government Endorsement cited with the enclosures in original are returned herewith.

for Chief Operation Engineer (South).

Encl:-
rr/2/7/-

Electricity - Restriction and Control - Mangalore Electric Supply Co. Ltd. - Supply to Govt. Ice and Fish Freezing Plant, Mangalore - Permitted

Read:

From the Mangalore Electric Supply Co. Ltd. Ref. No. MAN/1252/67/3 dt. 11-6-55.

From the CE(G) dv. No. 634-R/55-7 dt. 15-6-55.

From the Coe(S) dv. No. 2311-E/55-7, dt. 30-6-55.

Go. Ms. No. 2838 dt. 25-7-55.

The Govt. permit the Mangalore Electric Supply Co. Ltd. to supply electricity for a load of 1.28 H.P. to the Government Ice and Fish Freezing Plant, Mangalore, for all the 24 hours of the day, as in the application for permit enclosed, subject to the following conditions:-

(i) The maximum demand of the Consumer should be restricted to 60 K.W. at all times;

(ii) The supply is liable to be suitably restricted, staggered or cut off altogether, as the case may be, as and when the power position or any other emergency in the licensee's power house

warrants such a course of action.

7.7.55

21.7.55

Officer's Initials.

To:

The Mangalore Sl. Supply Co. Ltd., Mangalore
with application —
The CAIG — with application
The COE(SY).

2 Sets.

Note: The draft order above forwards the recommendation of the CAIG in his Lr. on p. 1 cf., and is subd. for approval.

2. I.L.C. Deptt. may see before issue.

7.7.55.

P.W.D. (W.) No.
51657-P/55-2.
7-7-55.

Ile 63588 HIII/55
9.7.55

ILC (HIII)

~~For~~ I.L.C. deptt. is not concerned with the proposal in this case, but if it is, may be returned to P.W. through Agri.

11 JUL 1955

11 JUL 1955
64543

Agri (Cs) Ile.(W) 63588 HIII

11.7.55

May be passed and passed on to P.W.D.

61090

P.W.D.

Agri (W) No. 64543 Cus/55

8.7.55

18 JUL 1955

16.7.55

Please see the notes of D.L.C. and Agri. Deptts. on p. 2 ante. The draft order on pp. 1–2 ante may be issued.

20.7.55.

20/7/55

20.7.55

21.7.55

[Issued as Circ. No. 2838, P.W., dt 25-7-55]